

Certificate of compliance

with the order 2.1 according to EN 10 204

Y-CY-JB / Y-CY-OB

We confirm that the above mentioned **PVC control and connection cable** is produced **in alignment with DIN VDE 0285-525-2-51 / DIN EN 50525-2-51** and tested according to DIN EN 50395, DIN EN 50396.

TECHNICAL DATA

Temperature range	flexible -15°C to +80°C fixed -40°C to +80°C
Nominal voltage	0.5 - 1.5 mm ² : AC U ₀ /U 300/500 V 2.5 - 185 mm ² : AC U ₀ /U 450/750 V 2.5 - 185 mm ² : fixed and protected installation AC U ₀ /U 600/1000 V

TESTS

flame-retardant acc. to DIN VDE 0482-332-1-2 / DIN EN 60332-1-2 / IEC 60332-1-2
certifications and approvals:
EAC

PROPERTIES

the materials used during manufacturing are cadmium-free, contain no silicone and are free from substances harmful to the wetting properties of lacquers



Product conforms with Low-Voltage Directive 2014/35/EU

HELU KABEL GmbH
Technical Department

This document is valid without signature

Date of issue
28.10.2024

Date of expiration
31.12.2026

Point of Contact
Christian Dettmer
Tel. +49 7150 9209-712
techsupport@helukabel.de
helukabel.com

HELU KABEL GmbH
Headquarters
Schloßhaldenstraße 10
71282 Hemmingen
Germany