

# Certificate of compliance

with the order 2.1 according to EN 10 204

**Y-CY-JZ / Y-CY-OZ**

We confirm that the above mentioned **PVC control and connection cable** is produced **in alignment with DIN VDE 0285-525-2-51 / DIN EN 50525-2-51** and tested according to DIN EN 50395, DIN EN 50396.

## TECHNICAL DATA

**Temperature range** flexible -15°C to +80°C  
fixed -40°C to +80°C

**Nominal voltage** AC U<sub>0</sub>/U 300/500 V

## TESTS

flame-retardant acc. to DIN VDE 0482-332-1-2 / DIN EN 60332-1-2 / IEC 60332-1-2  
certifications and approvals:  
EAC  
VDE-Reg.-No. 7032, valid for temperature range up to +70°C

## PROPERTIES

the materials used during manufacturing are cadmium-free, contain no silicone and are free from substances harmful to the wetting properties of lacquers



Product conforms with Low-Voltage Directive 2014/35/EU

**HELU KABEL GmbH**  
Technical Department

This document is valid without signature

**Date of issue**  
14.11.2022

**Date of expiration**  
31.12.2023

**Point of Contact**  
Christian Dettmer  
Tel. +49 7150 9209-712  
techsupport@helukabel.de  
helukabel.com

**HELU KABEL GmbH**  
Headquarters  
Schloßhaldenstraße 10  
71282 Hemmingen  
Germany