

# Certificate of compliance

with the order 2.1 according to EN 10 204

**HELUCONTROL® PUR-ORANGE-JZ / HELUCONTROL® PUR-ORANGE-OZ**

We confirm that the above mentioned **PUR control and connection cable** is produced **in alignment with DIN VDE 0285-525-1 / DIN EN 50525-1** and tested according to DIN EN 50395, DIN EN 50396.

## TECHNICAL DATA

**Temperature range** flexible -15°C to +80°C  
fixed -40°C to +80°C

**Nominal voltage** AC U<sub>0</sub>/U 300/500 V

## TESTS

oil-resistant acc. to DIN VDE 0473-811-404 / DIN EN 60811-404 / IEC 60811-404  
UV-resistant acc. to DIN EN ISO 4892-2  
weather-resistant acc. to DIN EN ISO 4892-2

## PROPERTIES

the materials used during manufacturing are cadmium-free, contain no silicone and are free from substances harmful to the wetting properties of lacquers



Product conforms with Low-Voltage Directive 2014/35/EU

**HELU KABEL GmbH**  
Technical Department

This document is valid without signature

**Date of issue**  
20.09.2023

**Date of expiration**  
31.12.2025

**Point of Contact**  
Christian Dettmer  
Tel. +49 7150 9209-712  
techsupport@helukabel.de  
helukabel.com

**HELU KABEL GmbH**  
Headquarters  
Schloßhaldenstraße 10  
71282 Hemmingen  
Germany