

Certificate of compliance

with the order 2.1 according to EN 10 204

PUR-YELLOW

We confirm that the above mentioned **PUR control and connection cable** is produced **in alignment with DIN VDE 0285-525-1 / DIN EN 50525-1** and tested according to DIN EN 50395, DIN EN 50396.

TECHNICAL DATA

Temperature range	flexible -15°C to +80°C fixed -40°C to +80°C
Nominal voltage	AC U ₀ /U 300/500 V

TESTS

UV-resistant acc. to DIN EN ISO 4892-2
weather-resistant acc. to DIN EN ISO 4892-2
certifications and approvals:
EAC

PROPERTIES

the materials used during manufacturing are cadmium-free, contain no silicone and are free from substances harmful to the wetting properties of lacquers



Product conforms with Low-Voltage Directive 2014/35/EU

HELU KABEL GmbH
Technical Department

This document is valid without signature

Date of issue
23.01.2025

Date of expiration
31.12.2026

Point of Contact
Christian Dettmer
Tel. +49 7150 9209-712
techsupport@helukabel.de
helukabel.com

HELU KABEL GmbH
Headquarters
Schloßhaldenstrasse 10
71282 Hemmingen
Germany