

Certificate of compliance

with the order 2.1 according to EN 10 204

H07G-K / 07G-K

We confirm that the above mentioned **Rubber single core** is produced: **H07G-K acc. to DIN VDE 0285-525-2-42 / DIN EN 50525-2-42; 07G-K in alignment with DIN VDE 0285-525-2-42 / DIN EN 50525-2-42** and tested according to DIN EN 50395, DIN EN 50396.

TECHNICAL DATA

Temperature range	flexible -5°C fixed -40°C
Permissible operating temperature of the conductor	+110°C
Nominal voltage	AC U ₀ /U 450/750 V

TESTS

certifications and approvals:

H07G-K: HAR

H07G-K: EAC



Product conforms with Low-Voltage Directive 2014/35/EU

HELU KABEL GmbH
Technical Department

This document is valid without signature

Date of issue
06.10.2022

Date of expiration
31.12.2023

Point of Contact
Christian Dettmer
Tel. +49 7150 9209-712
techsupport@helukabel.de
helukabel.com

HELU KABEL GmbH
Headquarters
Schloßhaldenstraße 10
71282 Hemmingen
Germany