

# Certificate of compliance

with the order 2.1 according to EN 10 204

**JZ-602-CY / OZ-602-CY**

We confirm that the above mentioned **PVC control and connection cable** is produced **acc. to UL-Std. 758 (AWM) Style 2587, CSA-Std. C22.2 No. 210 - AWM I/II A/B** and tested according to DIN EN 50395, DIN EN 50396.

## TECHNICAL DATA

**Temperature range** flexible -10°C to +90°C  
fixed -40°C to +90°C

**Nominal voltage** UL (AWM) AC 600 V

## TESTS

flame-retardant acc. to DIN VDE 0482-332-1-2 / DIN EN 60332-1-2 / IEC 60332-1-2, UL VW-1, CSA FT1  
certifications and approvals:  
EAC

## PROPERTIES

the materials used during manufacturing are cadmium-free, contain no silicone and are free from substances harmful to the wetting properties of lacquers



Product conforms with Low-Voltage Directive 2014/35/EU

**HELU KABEL GmbH**  
Technical Department

This document is valid without signature

**Date of issue**  
02.03.2023

**Date of expiration**  
31.12.2024

**Point of Contact**  
Christian Dettmer  
Tel. +49 7150 9209-712  
techsupport@helukabel.de  
helukabel.com

**HELU KABEL GmbH**  
Headquarters  
Schloßhaldenstrasse 10  
71282 Hemmingen  
Germany