Certificate of compliance

with the order 2.1 according to EN 10 204

H05VV-F / 05VV-F

We confirm that the above mentioned **PVC connection cable** is produced: **H05VV-F acc. to DIN VDE 0285-525-2-11 / DIN EN 50525-2-11; 05VV-F in alignment with DIN VDE 0285-525-2-11 / DIN EN 50525-2-11** and tested according to DIN EN 50395, DIN EN 50396.

TECHNICAL DATA

Temperature range	flexible -5°C to +70°C fixed -40°C to +70°C
Nominal voltage	AC U_0/U 300/500 V

TESTS

flame-retardant acc. to DIN VDE 0482-332-1-2 / DIN EN 60332-1-2 / IEC 60332-1-2
certifications and approvals:
H05VV-F: HAR
EAC

PROPERTIES

the materials used during manufacturing are cadmium-free, contain no silicone and are free from substances harmful to the wetting properties of lacquers

CE Product conforms with Low-Voltage Directive 2014/35/EU

HELU KABEL GmbH
Technical Department

This document is valid without signature

Date of issue
06.08.2026

Date of expiration
31.12.2028

Point of Contact
Christian Dettmer
Tel. +49 7150 9209-712
techsupport@helukabel.de
helu.com

HELU KABEL GmbH
Headquarters
Schloßhaldenstraße 10
71282 Hemmingen
Germany

M29450