

# Certificate of compliance

with the order 2.1 according to EN 10 204

## H05RR-F

We confirm that the above mentioned **Rubber connection cable** is produced **acc. to DIN VDE 0285-525-2-21 / DIN EN 50525-2-21** and tested according to DIN EN 50395, DIN EN 50396.

### TECHNICAL DATA

Temperature range	flexible -25°C to +60°C fixed -30°C to +60°C
Permissible operating temperature of the conductor	+60°C
Nominal voltage	AC U <sub>0</sub> /U 300/500 V

### TESTS

flame-retardant acc. to DIN VDE 0482-332-1-2 / DIN EN 60332-1-2 / IEC 60332-1-2  
certifications and approvals:

HAR  
EAC



Product conforms with Low-Voltage Directive 2014/35/EU

**HELU KABEL GmbH**  
Technical Department

This document is valid without signature

**Date of issue**  
27.03.2026

**Date of expiration**  
31.12.2028

**Point of Contact**  
Christian Dettmer  
Tel. +49 7150 9209-712  
techsupport@helukabel.de  
helu.com

**HELU KABEL GmbH**  
Headquarters  
Schloßhaldenstraße 10  
71282 Hemmingen  
Germany