

Certificate of compliance

with the order 2.1 according to EN 10 204

HELUTHERM® 400-MULTI-ES

We confirm that the above mentioned **Control and connection cable** is produced **acc. to company specifications** and tested according to DIN EN 50395, DIN EN 50396.

TECHNICAL DATA

Temperature range	fixed -60°C to +400°C
Nominal voltage	AC U ₀ /U 300/500 V

TESTS

halogen-free acc. to DIN VDE 0482-754-1 / DIN EN 60754-1 / IEC 60754-1
certifications and approvals:
EAC



Product conforms with Low-Voltage Directive 2014/35/EU

HELUX KABEL GmbH
Technical Department

This document is valid without signature

Date of issue
27.03.2026

Date of expiration
31.12.2028

Point of Contact
Christian Dettmer
Tel. +49 7150 9209-712
techsupport@helukabel.de
helu.com

HELUX KABEL GmbH
Headquarters
Schloßhaldenstrasse 10
71282 Hemmingen
Germany